


MOSSES, SCUMS AND ALGAE HAD GROWN ON THE WET, FLAT, UPPER SURFACES OF THE CORNICE

50mm X 50mm CORRODED W.I. BAR EXPANDED, SPALLED STONE FROM THE FACADE AND PUSHED THE SOFFIT DOWN



MANY VERTICAL S MISSING OR LOO

CODE 6 LEAD TO VERTICAL FACE OF BLOCKING COURSE

LIME MORTAR FILLET FLAUNCHING ON CORONA COURSE COVERED WITH CODE 8 LEAD

COLLAPSING STONE HUNG FROM THE W.I. BAR AS PER DETAIL A

COLLAPSING STONE PINNED TO RUBBLE CORE WITH 400mm LONG, 12mm  $\phi$  S.S. BAR

